

May 3, 2011

CRIVITZ REDI-MIX CO.
A DIV. OF MCC, INC.
DAVE URBAN
2600 N ROEMER RD
PO BOX 1137
APPLETON WI 54911

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: CRIVITZ REDI-MIX CO.
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING OR PUMP
Model Number(s): 1200/800 (804/1260 gals. actual capacity)
(49.5 IN. L.L., 25.5/16.3 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 991 G.P.D. WHEN
USED AS A SEPTIC/SEPTIC TANK OR 605 G.P.D. WHEN USED AS A SEPTIC/PUMP
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER;
TANK DIMENSIONS = 134 IN. L X 69 IN. W X 49.5 IN. H)
Product File No: 20110156

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - 3/4" diameter opening in the access riser.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- **BEDDING AND BACKFILL: Tank bedding must be 3 in. of compacted sand, gravel or lime rock of which 100% will pass through 1/2-inch screen. Backfill material must be material that 100% will pass through a 4-inch screen and tamped into place.**

CRIVITZ REDI-MIX CO.

Page 2

May 3, 2011

Product File No: 20110156

This approval supersedes the approval issued on 1/19/2006 under product file number 20050780.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050780.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV